

## EC DECLARATION OF CONFORMITY

Product Group 46

(yy) = year CE marking first affixed

SS-PIR-SW-01 Surface mount switching PIR sensor -(15) SF-PIR-SW-01 Flush mount switching PIR sensor -(15)

The Helvar Limited equipment listed above conforms with the protection requirements of the Council Directive 2004/108/EEC, relating to Electromagnetic Compatibility, Council Directive 2006/95/EEC, relating to Low Voltage and Council Directive 2011/65/EC, relating to Restriction of Hazardous Substances, by the application of one or more of the following standards:

EN 60669-2-1:2004 + A12:2010 Switches for household and similar fixed installations – electronic switches

EN 55015:2013 Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment

Qualifications

To meet these standards the following conditions must be met:

• The equipment must be used in accordance with the manufacturer's instructions.

Signed

Paul Wilmshurst

Managing Director

17/08/15

On behalf of Helvar Limited.

helvar.com

Kull almil