freedom in lighting Helvar



Linear LED Module, LP Series

- High value 280 mm linear module, high efficacy up to 175 lm/W at Tc = 65 °C
- Homogenous light distribution, pitch 15,6 mm between LEDs
- Accurate initial colour consistency of MacAdam (SDCM) 3-step
- Modular product plaform for design flexibility
- Designed for easy installation and series connection
- Zhaga compliant dimensions
- Helvar LMC diffuser covers and mounting parts available
- Compatible with LEDiL optics*

*See page 5 for details







	Nominal colour	Luminous flux $(\Phi_{_{_{\boldsymbol{v}}}})$	Forward voltage (V _f)		Luminous efficacy	Power consumption	CRI	
	temperature	Tc = 65 °C	Tc = 65 °C	Tc = 25 °C	Tc = 65 °C	Tc = 65 °C		
	[K]	Typ. [lm]	Typ. [V]	Max. [V]	Typ. [lm/W]	Typ. [W]		
Efficient @ 250 mA								
LP-282-830-009A	3000	630			148			
LP-282-840-009A	4000	700	17.1	18.5	18.5	165	4.3	> 80
LP-282-850-009A	5000	675			159			
Nominal @ 350 mA								
LP-282-830-009A	3000	800			132			
LP-282-840-009A	4000	890	17.5	18.9	146	6.1	> 80	
LP-282-850-009A	5000	860			141			
Maximum @ 450 mA								
LP-282-830-009A	3000	990			124			
LP-282-840-009A	4000	1100	17.8	19.3	19.3 138 8.0	8.0	> 80	
LP-282-850-009A	5000	1060			133			

Tolerance for the values of CCT, luminous flux and forward voltage in the table is $< \pm 7 \%$

Electrical specifications

	LP-282		
Direct current supply only	Nominal	Max.	
Operating Current [mA]	350	450	
Operating Voltage [V]	17.5 ¹⁾	19.3 ²⁾	

¹⁾ At 350 mA, Tc = 65 °C ²⁾ At 450 mA, Tc = 25 °C

400 V 1) Maximum rated voltage in circuit

ESD protection tested:

(according to IEC 61547 cl 5.2) 2)

Air discharge 8 kV Contact discharge 4 kV IP rating

Photometric specifications

Colour consistency at initial time 3 MacAdam steps

Colour Rendering Index > 80 Beam angle 120°

Photobiological risk group RG1 unlimited

Lifetime specifications

Operating current	Temperature	L70B50	L70B20	L70B10	L80B50
Efficient	Tc = 65 °C	> 50 000	> 50 000	> 50 000	> 50 000
250 mA	Tc = 80°C	> 50 000	> 50 000	> 50 000	> 46 000
Nominal	Tc = 65 °C	> 50 000	> 50 000	> 50 000	> 50 000
350 mA	Tc = 80°C	> 50 000	> 50 000	> 50 000	> 45 000
Maximum	Tc = 65 °C	> 50 000	> 50 000	> 50 000	> 48 000
450 mA	Tc = 80°C	> 50 000	> 50 000	> 50 000	> 44 000

Lumen depreciation estimations in hours


Operating Conditions and Characteristics

Tp point (performance measurements) Tc = 65 °C Max. temperature at Tc point Ambient temperature range -20...+50 °C Storage temperature -20...+80 °C Humidity No condensation

¹⁾ Please refer to the LS/LP Series installation guide for details

²⁾ In addition, tested with 30kV contact discharge to terminals and Tc point





Length	279.8 ± 0.2 mm		
Width	23.8 ± 0.2 mm		
Thickness of PCB	1.6 ± 0.2 mm		
Height	6.2 ± 0.2 mm		

Packing details	1 Tray	1 Box		
Num. of modules	60	300		
ESD foam trays, antistatic bag and carton box				

Wiring specifications

Connector type Push-in connector Wire size $0.2 - 0.75 \; mm^2$, solid core 0.2 - 0.34 mm², stranded


Wire strip length 7 - 9 mm

Wire type Solid core and fine-stranded

Thermal Management


Tc (Tp) Point : See the below red mark.







Specification diagrams





FORWARD VOLTAGE VS FORWARD CURRENT





Information and conformity



LP-282A LED module is suited for built-in usage in luminaires. In order to have safe and reliable operation, the LED luminaires will need to comply with the relevant standards and regulations (e.g. IEC/EN 60598-1). The LED luminaire shall be designed to adequately protect the LED modules from dust, moisture and pollution. The luminaire manufacturer is responsible for the correct choice and installation of the LED module / LED driver combination according to the application and product datasheets. Operating conditions of the LED modules may never exceed the specifications as per the product datasheets.

HANDLING OF THE LED MODULES

LED modules contain components (LED packages, chips) that are sensitive for mechanical stress, electrostatic discharge (ESD) and chemical contaminants. Improper handling of the modules might cause damage or even destruction of the LED modules. Damaged LEDs may show some unusual characteristics such as increase in leakage current, lowered turn-on voltage, or abnormal lighting of LEDs at low current. Please follow following instructions and the precautions given in the product datasheets while handling and assembling Helvar LED modules.

Storage conditions

- Unused LED modules are recommended to stored carefully in an original sealed ESD package preventing moisture, pollutants or ESD to cause damage the module.
- -20...+80 °C • Storage temperature range:

Opening the package / resealing

• LED modules are kept in stable protected environment in the packaging, open the package only when you are ready to use the LED modules. If resealing of the original package is required remove excess air from the packaging and place the moisture absorber (silica-gel bag) in to the packaging and seal the ESD back with adhesive tape.

ESD precautions at luminaire assembly site

The LEDs are sensitive to the electrostatic discharge (ESD) and surge current. If voltage exceeding the absolute maximum rating is applied to LEDs, it may cause damage or even destruction to LED devices.

• IEC / EN 61340-5-1: Protection of electronic devices from electrostatic phenomena - General Requirements describes procedures for protection for damage caused by electrostatic discharge while handling electronic devices, following list lists basic protective measures described in the standard.

ESD protection measures in handling and assembling LED modules

- Employee training for correct handling.
- Personnel grounding via wrist band / footwear.
- ESD protective clothing / shoes.
- Handle LED modules only in ESD protected areas and workplaces.

CHEMICAL CONSIDERATIONS

Chemical substances may cause damage the LED module by causing discoloration, loss of luminous flux or total failure of the module.

Avoid materials and substances containing:

- VOCs Volatile Organic Compounds that may occur in adhesives or sealings, verify that the materials used in the luminaires are not causing VOCs
- Halogen compounds
- Chlorine
- Acetates
- Sulphuric compounds.

Never look directly into an operational LED module without suitable protective eye wear!

ELECTRIC & THERMAL CONSIDERATIONS

Wiring insulation

• According to recommendations in IEC / EN 60598.

Wire connections

- Please refer to LED driver datasheets connections diagram.
- Wrong polarity might damage the LED modules.

Choosing the LED driver

- To quarantee the safe and reliable operation of the LP series LEDmodules the LED driver must be provided with open and short
- LP series modules are designed to be used with constant current output type LED driver.

Electrical design, electrical safety

During the design it is luminaire manufacturers responsibility to follow the international and national electric design regulations and recommendations for the electric safety and luminaire protection. Electric safety classification and protection class is depending on:

- Actual luminaire design and safety classification
- LED driver insulation
- LED driver output isolation.

ALWAYS CHECK AND FOLLOW EXACT REGULATIONS FROM LATEST RELEVANT IEC / EN STANDARDS.

Maximum ambient and to temperature

- The maximum ambient temperature is a guideline given for builtin components such as LED modules. However, integrator must always ensure proper thermal management (i.e. mounting base of the module, possible heatsink, air flow etc.) so that the tc point does not exceed the tc max limit.
- Reliable operation is only guaranteed if the maximum to point temperature is not exceeded under the conditions of use.
- Lifetime is only guaranteed if the maximum to point temperature specified for lifetime is not exceeded under the conditions of use.

MECHANICAL CONSIDERATIONS

- While handling the LED modules avoid mechanical stress or pressure applied to the light emitting surface of the LEDs.
- Avoid dropping the modules.
- Bending of the modules is not permitted.
- Avoid touching the light emitting surface.
- Mechanical modifications (e.g. drilling, milling or sawing the module) are not permitted.

INSTALLATION CONSIDERATIONS

The LP series modules are basic isolated against ground and can be installed on properly insulated metal parts of the luminaire. We recommend using Helvar LMC mounting parts, plastic screws, clips or a combination of M4 metal screws and insulating plastic washers for safe operation.

Please follow regulations from IEC/EN 60598-1 for creepage and clearance requirements. More information in LS/LP Series installation guide, available on product website's Download & Links section.

Information and conformity



Conformity & standards

IEC / EN 62031
IEC / EN 62471
TR IEC / EN 62778

All data were deemed correct at time of creation. Helvar is not liable for errors or omissions.

Compatible LEDiL optics

Following LEDiL optics are compatible with LP-282A LED module. More information about LEDiL optics is available at www.LEDiL.com.

F15523_LINNEA-90
F15524_LINNEA-60
F15756_LINNEA-0
F15860_LINNEA-Z2T25
F15861_LINNEA-ZT25
F16048_LINNEA-UP